

Verification of Corrosion Resistance Performance Testing



Reference No.: 50251080 001

TÜV Rheinland verify that corrosion resistance performance for aluminum sheet of heat exchanger of air conditioner is satisfied requirements at test method B of ISO 21207 standard according to reference no. 50251080 001.

Holder : **LG Electronics Inc.**
84, Wanam-ro, Seongsan-gu, Changwon-si,
Gyeongsangnam-do, 51554, Korea

Product: **Aluminum sheet of heat exchanger of**
air conditioner

Identification: **Corrosion improved aluminum fin (Black II)**

Applicable Standard **Test method B of ISO 21207**
(Salt contaminated condition and
Severe industrial or traffic environment)

Claim Verified: **Resists 27 years of simulated**
severe corrosion

Acceptance Criteria **LG(70)-E-1026**

Date: 2019.05.10


Dong-Gyun Cheon

TÜV Rheinland Korea Ltd. – Seoul 07298 – Republic of Korea